

Exova Warringtonfire Aus Pty Ltd  
 Unit 2, 409-411 Hammond Road  
 Dandenong, Victoria 3175  
 Australia

T: +61 (0)3 9767 1066  
 F: +61 (0)3 9767 1001  
 E: market.pacific@exova.com  
 W: www.exova.com



Postal Address:  
 PO Box 4282  
 Dandenong South, Victoria 3164  
 Australia

Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF ASSESSMENT</b>	<b>CERTIFICATE No: SFC 30930800</b>	<b>Page 1 of 1</b>
---------------------------------------	-------------------------------------	--------------------

Report Sponsor	Certificate Issue Date
Forest and Wood Products Australia Limited Level 4, 10-16 Queen Street Melbourne, 3000	15/12/2014

**Introduction**

This certificate confirms the element of construction described below was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced assessment report for more information.

Referenced Report	Report Issue Date	Test Standard
EWFA 30930800	15/12/2014	AS1530.8.1-2007 as appropriate for decks

Description of Product		
Product Name	Assessed Construction	Rating
Jarrah and Karri Decking	Decking Size            85mm wide (min) × 20mm thick Decking Gap;            Nominally 3mm Subfloor Framing;      Enclosed Framing Species;        Radiata pine, Karri, Jarrah.	<b>BAL 29</b>

**Conditions/Validity**

**THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.**

Reference should be made to the relevant assessment report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
Phone / Fax	+61 (0) 3 9767 1000 / +61 (0) 3 9767 1001	
ABN	81 050 241 524	
Email / Home Page	<a href="http://www.exova.com">www.exova.com</a>	
Authorisation	Prepared By:  K. G. Nicholls	Reviewed By:  S. Hu